

Tratament chimic: LIPSA CIRCULATIE, SUPRAINCALZIRE REPETATA PANOURI SOLARE



CHIMIA
INSTALATIEI
TERMICE

Probleme tratate: ANTIGEL DEGRADAT, DEPUNERI ORGANICE, PRAF

Materiale: CUPRU / ALUMINIU / STICLA

CHECK SERVICE




Verificare parametrul fluid

CLEANEX SOLAR



Solutie 20-50%
(cca 5kg / 10l apa)



Recirculare: 30-50 min




Monitorizare: pH<5

NEUTRALIZER ALCALIN



Solutie 1-4%
(cca 150g / 10l apa)



Recirculare: 5-10 min



Clatire instalatie
pana la pH 6.5-7.5

SOLAR PROTECT S45



Incarcati instalatia
Asigura protectia
la -28°C
(nu se dilueaza)

CLEANEX PANSOL



Pulverizati o solutie de 15
30% pe suprafata
panourilor. Dupa 5-10 min
clatiti cu apa abundent.